

Electrical Equipment Testing (PAT) REPORT/CERTIFICATE

DETAILS OF CLIENT

Name: DJ Scott Dewing	Telephone No: 07817 909442
Address: 7 Abbott Way, Holbrook, Suffolk	Post Code: IP9 2FG

TEST EQUIPMENT DETAILS

Test equipment used: Seaward PrimeTest 100	Serial No 40M-0508	Date of Test: 15/02/2024
Tested by: Karl Semmence	No. of pages: 2	Next Test Due: 14/02/2025

ID Number	Class or Lead	Location	Description	Result P or F	Risk	Comment
1	Class I	Mobile	dB Technology ES1203 Bass Cab w amp	Pass	L	
6	Lead	Mobile	6 way extension lead	Pass	H	13A Surge Protected
8	Lead	Mobile	6 way extension lead	Pass	H	13A Surge Protected
9	Lead	Mobile	2 way extension lead	Pass	H	10A
10	Lead	Mobile	2 way extension lead	Pass	H	10A
11	Lead	Mobile	2 way extension lead	Pass	H	10A
12	Class II	Mobile	PSU	Pass	M	
14	Class II	Mobile	Samsung TV	Pass	M	
17	Class II	Mobile	PSU	Pass	M	
19	Lead	Mobile	IEC to Mains	Pass	H	13A
20	Lead	Mobile	IEC to Mains	Pass	H	13A
21	Lead	Mobile	IEC to Mains	Pass	H	13A
23	Lead	Mobile	Figure 8 to mains	Pass	H	3A
25	Lead	Mobile	Cloverleaf to mains	Pass	H	5A
27	Class II	Mobile	PSU	Pass	M	
28	Class II	Mobile	PSU	Pass	M	
29	Class II	Mobile	PSU	Pass	M	
40	Class I	Mobile	Haze Machine	Pass	M	
41	Class II	Mobile	PSU	Pass	M	
45	Lead	Mobile	Figure 8 to mains	Pass	H	3A
47	Lead	Mobile	2 way extension lead	Pass	H	13A (Renewed plug)
49	Lead	Mobile	6 way extension lead	Pass	H	Photo Booth 13A
50	Lead	Mobile	Figure 8 to mains	Pass	H	Photo Booth 3A
52	Lead	Mobile	Figure 8 extension lead	Pass	H	Photo Booth
53	Lead	Mobile	Figure 8 extension lead	Pass	H	Photo Booth
55	Class II	Mobile	White Light	Pass	H	Photo Booth
57	Class II	Mobile	White Light	Pass	H	Photo Booth
58	Class II	Mobile	White Light	Pass	H	Photo Booth
60	Class III	Mobile	Mini Mac PC	Pass	L	Photo Booth
61	Lead	Mobile	Apple Power Lead	Pass	H	Photo Booth
63	Class II FE	Mobile	PSU	Pass	L	Photo Booth
64	Class III	Mobile	TV Monitor	Pass	L	Photo Booth
66	Lead	Mobile	Figure 8 to mains	Pass	H	Photo Booth 3A
67	Class II	Mobile	Camera PSU	Pass	L	Photo Booth
74	Class II	Mobile	PSU	Pass	M	
75	Class III	Mobile	Senheisser Mcrophone Receiver	Pass	M	
76	Class I	Mobile	Alto Pro Battery speaker	Pass	M	
82	Class II	Mobile	Neutrix to Mains	Pass	H	13A
83	Class I	Mobile	Dance Floor Controller Box	Pass	H	
85	Lead	Mobile	2 way extension lead	Pass	H	13A
88	Class I	Mobile	Printer	Pass	M	Photo Booth
91	Class III	Mobile	Canon Camera	Pass	L	
95	Class I	Mobile	dB Technology ES1203 Bass Cab w amp	Pass	M	
96	Lead	Mobile	Cloverleaf to mains	Pass	H	5A
97	Class II FE	Mobile	Laptop PSU	Pass	M	
99	Class III	Mobile	Dell Laptop	Pass	L	
100	Class I	Mobile	Yamaha MG12XU Mixer	Pass	L	
102	Lead	Mobile	IEC to Mains	Pass	H	13A
103	Lead	Mobile	Cloverleaf to Mains	Pass	H	5A
104	Lead	Mobile	IEC to Mains	Pass	H	5A
106	Lead	Mobile	Figure 8 to mains	Pass	H	5A
107	Class II	Mobile	PSU	Pass	M	
108	Class III	Mobile	Wolfmix W1 Mixer	Pass	L	

Electrical Equipment Testing (PAT) REPORT/CERTIFICATE

DETAILS OF CLIENT

Name: DJ Scott Dewing	Telephone No: 07817 909442
Address: 7 Abbott Way, Holbrook, Suffolk	Post Code: IP9 2FG

TEST EQUIPMENT DETAILS

Test equipment used: Seaward PrimeTest 100	Serial No 40M-0508	Date of Test: 15/02/2024
Tested by: Karl Semmence	No. of pages: 2	Next Test Due: 14/02/2025

ID Number	Class or Lead	Location	Description	Result P or F	Risk Comment
109	Lead	Mobile	Figure 8 to mains	Pass	H 5A
110	Lead	Mobile	IEC to Mains	Pass	H 13A
111	Lead	Mobile	IEC to Mains	Pass	H 5A
113	Lead	Mobile	6 way extension lead	Pass	H 13A Repaired wires in plug
114	Lead	Mobile	Neutrik to Neutrik lead	Pass	H
115	Lead	Mobile	Mains to Neutrik lead	Pass	H 13A
116	Lead	Mobile	6 way extension lead	Pass	H 13A
117	Lead	Mobile	Mains to Neutrik lead	Pass	H
118	Lead	Mobile	Neutrik to Neutrik lead	Pass	H 5A
119	Lead	Mobile	Figure 8 to mains	Pass	H 5A
120	Class II	Mobile	PSU	Pass	M
121	Lead	Mobile	Mains to Neutrik lead	Pass	H 13A
122	Class I	Mobile	ADJ Focus Spot 5Z	Pass	M
123	Class I	Mobile	ADJ Focus Spot 5Z	Pass	M
124	Lead	Mobile	IEC to Mains	Pass	H 5A
125	Class III	Mobile	Pioneer DJ DDJ FLX10 Controller	Pass	L
126	Class III	Mobile	PC	Pass	M
127	Lead	Mobile	Cloverleaf to mains	Pass	H 5A
128	Class II FE	Mobile	PSU	Pass	M
129	Lead	Mobile	2 way extension lead	Pass	H 13A
130	Class III	Mobile	Dell Laptop	Pass	M

* All items Tested as made available

* Items tested in line with '5th Edition Code of Practice for In-Service Inspection and Testing of Electrical Equipment'